

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E92044  
**Report Reference** E92044-20060602  
**Issue Date** 2021-JULY-29

**Issued to:** HOFFMAN ENCLOSURES INC  
2100 Hoffman Way  
Anoka, MN 55303-1738 United States

**This certificate confirms that representative samples of** INDUSTRIAL CONTROL PANELS  
See Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508A- Industrial Control Panels, UL 50E-Standard for Enclosures for Electrical Equipment

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E92044  
**Report Reference** E92044-20060602  
**Issue Date** 2021-JULY-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Enclosure Type UCP:

UCP320, UCP430, UCP540, UCP640, UCP750, UCP860, UCP1080

## Ratings:

These enclosures are rated: 3, 3R, 3S, 4, 4X, 12, 13.


---

## Enclosures Type UDP/UDPT:

UDP5050, UDP5075, UDP7550, UDP7575, UDP75100, UDP75125, UDP10050, UDP10075, UDP100100, UDP100102, UDP100125, UDP12575, UDP125100, UDP125102, UDPT5050, UDPT5075, UDPT7550, UDPT7575, UDPT75100, UDPT75125, UDPT10050, UDPT10075, UDPT100102, UDPT100125, UDPT12575, UDPT125100, UDPT125102.

## Ratings:

	Single Door	Single Door With Observation Window	Double Door	Coupled Enclosure	Coupled Enclosure With Observation Window
PUR	Type 3, 3R, 3S, 12, 12K and 13	Type 3, 3R, 3S	Type 3R	Types 3, 3R, 3S, 12, 12K and 13.	Types 3, 3R, 3S.
Alternate Gasket	Type 3, 3R, 3S, 4, 4X, 12, 12K and 13	Type 3, 3R, 3S, 4, 4X	N/A	Types 3, 3R, 3S, 4, 4X, 12, 12K and 13	Types 3, 3R, 3S, 4, 4X
With Drain ventilator	Type 1, 3, 3R, 3S,	Type 1, 3, 3R, 3S,	N/A	Type 1, 3, 3R, 3S,	Type 1, 3, 3R, 3S,



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

