



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER

SC ELDON SRL
Calle Bruxelles no.4
Graells & Llonch Prejmer Industrial Park
Prejmer County
507165 postal code
Brasov city
Romania

**PRODUCT
DESCRIPTION**

Wall Mounting Enclosures

TYPE

MAM series, single door
Degree of protection IP 55 (Cat. 2).

MAS series, Mild steel, single door
Degree of protection IP 66.

MAD series, mild steel, double door
Degree of protection IP 55 (Cat. 2)

MAP series, Mild steel, single door
Degree of protection IP 66

Certificate No.

19/30018

Issue Date

21 October 2019

Expiry Date

31 March 2024

Sheet

1 of 3



(top or bottom hinged).

ASR series, stainless steel (304S15 & 316S16), single door
Degree of protection IP 66.

ADR series, stainless steel (304S15 & 316S16), double door
Degree of protection IP 55 (Cat. 2).

KGR series, stainless steel (304S15 & 316S16), single door
Degree of protection IP 66.

KGT series, mild steel plate, single door
Degree of protection IP 66.

KLR series, stainless steel (304S15 & 316S16), single door
Terminal boxes
Degree of protection IP 66.

KLT series, mild steel, single door
Terminal boxes
Degree of protection IP 66.

TEN series, mild steel, including 19" profiles, single door
Degree of protection IP 30.

TED series, mild steel, including 19" profiles, single door
Degree of protection IP 30.

TEP series, mild steel, including 19" profiles, single door
Degree of protection IP 30.

ADDITIONAL ITEM:

AFS series, stainless steel (304S15 & 316S16), single door
Degree of protection IP 66.

**SPECIFIED
STANDARD**

EN 60529
IEC 60529

Certificate No.

19/30018

Issue Date

21 October 2019

Expiry Date

31 March 2024

Sheet

2 of 3

G.J.Vromans
Type Approval Department
Lloyd's Register EMEA/Rotterdam Office

IEC 439
EN 60439

APPLICATION

For Marine, Offshore and Industrial use

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. ROT.TA. BBO1602085 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No.94/30014 to which this extension should be attached.

Certificate No.	19/30018
Issue Date	21 October 2019
Expiry Date	31 March 2024
Sheet	3 of 3