


## FORM 10

Aon File Reference: BB019\_\_\_\_\_

<b>LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT</b> As per section 114 of NZS 4541:2020 and NZS4515:2009 Appendix G	
This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated 19 January 2023 this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2020 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.	
Item Pipe Hanger Components	
For use as gravity hangers	
Certificate number BB019	Effective from 25 January 2023
Manufacturer / Supplier: Erico/nVent	
Make nVent Caddy	
Model CMP10, CMP12, VMP10, VMP12, Eric15 60-165, Eric18 60-273, MPZ 20-50, HDN 081-173	
Reference information: nVent Caddy manufactures datasheets; SGS test reports dated 8 Dec 2022, 15 Dec 2022, 19 Dec 2022, 21 Dec 2022, 22 Dec 2022, 26 Dec 2022; FM listing	
Range limitations	
Hanger load limits are based upon being spaced per NZS4541:2020 table 4.7.	
Restrictions and warnings	
Special conditions	
	
Signed	Date 27 January 2023
Name IANZ Approved Signatory: Stephen Ridder	Designation Fire Protection Engineer