

## Declaration of Compliance

NO. OF PAGES

We: nVent HOFFMAN  
Pº de la Finca 1, Ed 3  
Madrid 28223

1 (1)

declare under our sole responsibility that the product ranges

**MCS, MCD, MKS, MKD, EKS, EKD, Mild steel floorstanding enclosures**  
**MCSS, MCDS, EKSS, EKDS, Stainless steel floorstanding enclosures**  
**MAS, MAD, MAP, Mild steel wall mounted enclosures**  
**ADR, AFS, ASR, Stainless steel wall mounted enclosures**  
**STB, Mild steel terminal boxes**  
**SSTB, Stainless Steel terminal boxes**

to which this declaration relates, comply with the relevant requirements stated in the standard IEC 61439-1&2 :2011 (Low-voltage switchgear and controlgear assemblies – Part 1: General rules) for empty enclosures:

**Section 8.1 Strength of material and parts**

**Section 8.2 Degree of protection**

The compliance has been verified through the empty enclosures certification following the standard IEC 62208:2011 (Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements), which has been issued by DEKRA in the following certificates:

**KEMA Certificate 2171237.01**

MAS, MAD, MAP, ASR, ADR, AFS, MCS, MCD, MKS, MKD, MCSS, MCDS

**KEMA Certificate 2171237.02**

EKS, EKD, EKSS, EKDS

**KEMA Certificate 2171237.03**

STB, SSTB

In addition, nVent HOFFMAN also declares that an enclosures assembly, built using nVent HOFFMAN enclosures and accessories, and following the mounting instructions available on Eldon's website, complies with IEC 61439-1&2:2011 (Low-voltage switchgear and controlgear assemblies).



Madrid, 20<sup>th</sup> February 2017

José Antonio Rodríguez Salvador,  
Product Manager