

Declaration of Compliance

NO. OF PAGES

We: nVent HOFFMAN
Pº de la Finca 1, Ed
3 Madrid 28223

1 (1)

declare under our sole responsibility that the product ranges

MPC, MPCS, MPG, MPGS, Consoles

to which this declaration relates, comply with the relevant requirements stated in the standard IEC 61439-1&2 :2011 (Low-voltage switchgear and controlgear assemblies – Part 1: General rules) for empty enclosures:

Section 8.1 Strength of material and parts


Section 8.2 Degree of protection

The compliance has been verified through the empty enclosures certification following the standard IEC 62208:2011 (Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements), which has been issued by DEKRA in the following certificates:

KEMA Certificate 95.4086.03

MPC, MPCS, MPG, MPGS

In addition, nVent HOFFMAN also declares that an enclosures assembly, built using nVent HOFFMAN enclosures and accessories, and following the mounting instructions available on Eldon's website, complies with IEC 61439-1&2:2011 (Low-voltage switchgear and controlgear assemblies).

A handwritten signature in blue ink, appearing to be "Nicolás Mediavilla Abellán".

Madrid, 3rd May 2017

Nicolás Mediavilla Abellán,
Product Manager