



# Certificate of Compliance

**Certificate:** 2251273

**Master Contract:** 161241

**Project:** 80072223

**Date Issued:** 2021-03-03

**Issued To:** nVent Thermal LLC  
899 Broadway Street  
Redwood City, California, 94063  
United States

**Attention:** James Lim

*The products listed below are eligible to bear the CSA Mark shown*

**Issued by:** *Johann Borabon*  
Johann Borabon



## **PRODUCTS**

### **CLASS – 2872 01 - HEATERS Cable and Cable Sets**

Self-regulating heating cable set, “RaySol®”, Cat. Nos. RaySol-1 and RaySol-2, floor heating and freezer frost heave prevention systems, embedded in concrete or mortar, attached to bottom of concrete floor or placed in conduit embedded in concrete; rated 120V or 208-277V; max continuous exposure temperature 65°C; 16.5 W/ft @ 5°C; max rated current 24A, minimum installation temperature -18°C; Usage Marking: -W.

Connection Kits: FTC-P Power Connection and End Seal Kit, FTC-XC Power Connection and End Seal Kit, FTC-HST-PLUS Splice Kit and RayClic-E End Seal Kit.

## **APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 130-16 - Requirements for Electrical Resistance Trace Heating and Heating Device Sets