

CERTIFICATE

NO. OF PAGES

1 (1)

We: nVent HOFFMAN
Pº de la Finca 1, Ed
3 Madrid 28223

declare that the product/equipment

UDP, Uniplast Enclosure Modular Version

UDPT, Uniplast Enclosure Modular Version

provided that it is installed, maintained and used in the application for which it has been created, with respect of the “professional practices”, relevant installation standards and manufacturer’s instructions,

- Single plain door enclosures, have a degree of protection of IP65, according to IEC60529.
- Double door enclosures have a degree of protection of IP54, according to IEC60529.
- Enclosures with transparent window have a degree of protection of IP54, according to IEC60529.

Madrid, 1st February 2013

Product Management

This certificate is provided at the request of the consumer. The certificate is valid for the product or equipment which is sold on the date mentioned above. nVent HOFFMAN reserves the right to modify or improve at any time the design or characteristics of the type of product or equipment referred to herein. This certificate will not apply to products or equipment which were modified or improved in any way after the date mentioned herein.