




Projekt/Project: Seismic test on Cabinet Varistar CP

Verantwortliche Abteilung: Responsible Department:	TACC05	IABG-Projektleiter: IABG Project Manager:	N.M. Bektas
Auftraggeber: Customer:	Schroff SAS	IABG-Auftragsnummer: IABG Contract No.:	K-15460:01
Ansprechpartner AG : Customer Contact :	Daniel Thomas	IABG-Angebotsnummer: IABG-Proposal no.:	TAPC01_22040009_V01
Seitenanzahl / Total pages :	17	Bestell-Nummer Kunde Order no.:	4502560681

Projekthalt: Project content:	Uniaxial sine sweep tests and uniaxial seismic tests
Prüfumgebung: Test equipment:	Test bench LiMAS (Light Multi-Axis Shaker)
Normen: Standards:	<ul style="list-style-type: none"> DIN EN 60068-2-6 (2008); Environmental testing – Part 2-6: Tests - Test Fc: Vibration (sinusoidal) GR-63-core (2017); NEBS™ Requirements Physical Protection; chapter 5.4.1 Earthquake Test Methods
Prüfling: Equipment under Test EuT:	<ul style="list-style-type: none"> Varistar CP Seismic Cabinet (see Figure 1 and Annex) Identification no: "VCP Seismic EMC 42U 2000H 600W 600D" Drawing no: "10630-050_BET.pdf" IABG-identification no: 221011-TAF4-as-01
Hersteller: Manufacturer:	Schroff SAS
Prüfungen: Tests:	<p>Uni-axial sine sweep according GR-63-Core: 5.4.1.5 (2017) and DIN EN 60068-2-6</p> <ul style="list-style-type: none"> Excitation Amplitude: 1 m/s² (X/Y/Z directions) Frequency range: 1 - 50 Hz Directions: successively in X, Y and Z Reference Point: Shake Table Sensor Sweep Velocity: 1 oct./min <p>Uniaxial seismic test according GR-63-Core; 5.4.1 (2017)</p> <ul style="list-style-type: none"> Excitation: uniaxial Signalform: VERTEQII, Zone 4 "highest risk areas" Frequency range: 2 to 50 Hz (due to shaker limits) Zero Point Acceleration: 1.6 g (1 g = 9.81 m/s²) Test configuration: Frame Level Test directions: X; Y; Z Reference Point: Shake Table Sensor
Prüfaufbau: Test setup:	<ul style="list-style-type: none"> The EuT is mounted onto the ground plate similar to its normal use, with 4 screws (M12; 120Nm, class 10.9). The ground plate is fixed to the shake table with 9 screws (M16; 190 Nm, class 10.9). Pictures from the test setup are listed on page 2. Load washer application on M12 screw and string pots on the top of EuT in x-y directions.
Ergebnisse: Results:	<ul style="list-style-type: none"> No functional tests were required. There were no deformations / cracks observed. Max. displacement X-direction: 17.2 mm; Y-direction: 18.4 mm

Head Of Component Center		Teamleiter (Team leader)		Projektleiter (Project manager)	
Dr. S. Rödling	Date/Datum	A. Simon	Date/Datum	N.M Bektas	Date/Datum
	21.11.2022		21/Nov/2022		21.11.2022

Bilder vom Prüfaufbau / Pictures from the test setup



Figure 1: Test Setup and Measurement Points A-B; EuT rear view



Figure 2: Load washer application



Figure 3: String-Pot Application in X-Y directions



Figure 4: The cabinet with dummy weights (see Annex for weight distribution)

Ergebnisse / Results:

- Time histories of sine sweep tests
- TRS-RRS-comparison in x-y-z-directions
 - o Blue-curve: RRS X/Y/Z 130%
 - o Red-curve: RRS X/Y/Z 100%
- Time histories of seismic tests in x-y-z directions; min./max. values; STS, sensor A and B, load washer and string pots

Bemerkung / Remark: Uni-axial seismic test X (test #04) is not valid, due to the malfunction of the sensor channel. This was solved, and the test was repeated, see test #05.

Sensoren und Kalibrierung / Sensors and calibration :

Serial Number	Definition	Range	Measuring Point	Next calibration
20-40440 X/Y/Z	Shake table sensor	± 100 m/s ²	Below table surface	01.2023
13-01580 X/Y/Z	Acc. Sensor "A"	± 500 m/s ²	Top left rear	01.2023
13-01581 X/Y/Z	Acc. Sensor "B"	± 500 m/s ²	Middle left rear	01.2023
20015190303	String pot SP_X	± 250 mm	Top of frame	06.2024
20015090297	String pot SP_Y	± 250 mm	Top of frame	06.2024
252610863	Load washer KMR/100 kN	0-100 kN	M12 screw between adapter plate and frame	11.2022

Anhänge (12 Seiten) / Annex (12 pages):

- Transfer functions calculated out of the sine sweep tests
- Time-history-plots of the sine sweep tests
- TRS-RRS comparison incl. time-history-plot of the shake table sensor from the seismic loads
- Time-history-plots from the seismic loads
- Customer documentation

Transfer function

Client: Schroff SAS

Test #: 01

excitation: sine sweep X

direction of measurement: X

measuring points: MP A and B




Figure 5: Transfer functions; sine sweep X; MP A and B; #01

Transfer function

Client: Schroff SAS

Test #: 02

excitation: sine sweep Y

direction of measurement: Y

measuring points: MP A and B




Figure 6: Transfer functions; sine sweep Y; MP A and B; #02


Transfer function

Client: Schroff SAS**Test #: 03**

excitation: sine sweep Z

direction of measurement: Z

measuring points: MP A and B

**Figure 7: Transfer functions; sine sweep Z; MP A and B; #03**

Measurement

Client: Schroff SAS

excitation: sine sweep test X

measuring points: STS, MP A-B

Test #: 01

direction of measurement: X




Figure 8: Sine sweep X direction; time-histories; STS and MP A and B; #01

Measurement

Client: Schroff SAS

excitation: sine sweep test Y

measuring points: STS, MP A-B

Test #: 02

direction of measurement: Y




Figure 9: Sine sweep Y direction; time-histories; STS and MP A and B; #02

Measurement

Client: Schroff SAS

excitation: sine sweep test Z

measuring points: STS, MP A-B

Test #: 03

direction of measurement: Z




Figure 10: Sine sweep Z direction; time-histories; STS and MP A and B; #03

Responsespectrum

Client: Schroff SAS



Test #: 04

excitation: uni-axial seismic X

direction of measurement: X

measuring points: STS

invalid



Filename: 20221011-100415_Seismik_110p_X.rpc

Figure 11: Seismic test X, Time-histories, min/max values and TRS-RRS; STS_X; #04, not valid

Responsespectrum



Client: Schroff SAS

Test #: 05

excitation: uni-axial seismic X

direction of measurement: X

measuring points: STS



Filename: 20221011-102758_Seismik_105p_X.rpc

Figure 12: Seismic test X, Time-histories, min/max values and TRS-RRS; STS_X; #05

Responsespectrum



Client: Schroff SAS

Test #: 06

excitation: uni-axial seismic Y

direction of measurement: Y

measuring points: STS



Filename: 20221011-103258_Seismik_110p_Y.rpc

Figure 13: Seismic test Y, Time-histories, min/max values and TRS-RRS; STS_Y; #06

Responsespectrum



Client: Schroff SAS

Test #: 07

excitation: uni-axial seismic Z

direction of measurement: Z

measuring points: STS



Filename: 20221011-104304_Seismik_110p_Z.rpc

Figure 14: Seismic test Z, Time-histories, min/max values and TRS-RRS; STS_Z; #07

Measurement

Client: Schroff SAS

Test #: 05/06/07

excitation: uni-axial seismic tests X-Y-Z

direction of measurement: X-Y-Z

measuring points: STS, MP A-B, Load washer and string pots







Figure 15: Seismic test X,Y and Z time-histories; STS and MP A and B; String-pot X-Y and load washer; #05 to 07


25/10/2022
 Toute communication ou reproduction de ce document, toute exploitation ou communication de son contenu sont interdites, sans autorisation expresse. Tout manquement à cette règle est illégal et expose l'auteur à des poursuites judiciaires. Les droits réservés pour le cas de la délivrance d'un brevet, d'un modèle d'utilité ou d'un modèle de présentation.
 The reproduction, distribution and utilization of this document as well as the communication of its contents to others without express authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent, utility model or design.
 print
 25/10/2022



NOMENCLATURE / BILL OF MATERIAL			
POS	REFERENCE	DESIGNATION / DESCRIPTION	QTE / QTY
1	2063036605	FRAME SEISMIC 42U 2000H 600W 600D	1
2	2163046405	EMC GASKETING KIT EN45545	1
3 (NON REPRÉSENTÉ / NOT SHOWN)	2463000105	EARTHING KIT 4MM²	1
4	2163055805	TOPCOVER 600W600D EMC	1
5	2463003005	LIFTING EYES M12	1
6	2163062905	BOTTOM PLATE 600W600D EMC	1
7	2163011005	PLINTH SEISMIC COVER 600W 600D	1
8	2313008105	DEPTH MEMBER 3-ROW 600D	3
9	2313003505	PAN/SLIDE MOUNT 19"42U ALZ	2
10	2163052905	FULL DOOR 2000H600W CEM	1
11	2463014305	DOOR REINFORCEMENT KIT 600W	1
12	2163055305	REAR PANEL 2000H 600W EMC	1
13	2163047405	SIDE PANEL 2000H600 EMC	1

* : Points de fixation des montants 19"
 * : Fixing points of the 19" panel mounts

Utilisation initiale / Initial use	VARISTAR CP	Echelle / Scale	1:5	Surface / Surface	mm²	Volume / Volume	mm³	Masse / Mass	-g
Matériau / Material		Tolérance générale / General tolerance: ISO 2768-mS							
Nom de base / Base part		Epaisseur / Thickness							
Libré / Approved	19/10/2022	MARCINKOW.	Designation: VCP 42U 2000H 600W 600D CEM SISMIC						
Norme / Conformity	19/10/2022	FOJT	Titre: VST CP 42U 2000H 600W 600D EMC SEISMIC						
Verifié / Checked	19/10/2022	MARCINKOW.	Modèle de référence / Reference model: 10630-050_BET						
Conçu / Drawn	19/10/2022	FOJT	Page / Page: 1/1						
Index / Rev.	ECO-No / ECO-No	Date / Date	Nom / Name	Modèle 3D / 3D-Model: 10630-050_BET					
A			4			3			2



A (mm)	M3 (kg)	M4 (kg)	M5 (kg)	Total load (kg)
265,9	25 x 4 positions	90	60	250