



HOFFMAN ENCLOSURES, INC.
2100 Hoffman Way
Minneapolis, MN 55303-1745, USA
+1.763.421.2240 main

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: ASB**3R, ASB**4R (Bulletin S90B)

Equipment Description: Hoffman Splitter Box, Type 1

Enclosure Rating : CSA Type 1

Enclosure Certification: CSA C22.2 No. 76-14

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

Applicable Standards: CAN/CSA C22.2 No. 76-14 – Splitters
CAN/CSA C22.2 No. 40-1989(R2014) – Cutout, Junction, Pull Boxes

Authorized by:

5/22/2020 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

Subject to Change Without Notice

DOC: CERT-00269-B



Certificate of Compliance

Certificate: 1408854 **Master Contract:** 151630 (042184_C_000)
Project: 70177569 **Date Issued:** 2018-05-01
Issued to: Hoffman Enclosures Inc.
2100 Hoffman Way
Anoka, Minnesota 55303-1745
USA
Attention: Glen Kampa

The products listed below are eligible to bear the CSA Mark shown



Issued by: Frank Gessner
Frank Gessner

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 76-14 - Splitters
CSA C22.2 No. 40-1989 (R2014) - Cutout, Junction and Pull Boxes