

## Declaration of Conformity

Issued by Manufacturer  
Hoffman Enclosures, Inc.

2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.

declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models: F\*\*\*\*SC (Bulletin F20SC)  
Equipment Description: Hoffman Screw Cover Wiring Trough  
Enclosure Certification: UL870 Listed E27524

File E27524 Vol. 1 Sec. 1 Page 1 Issued: 1963-06-27  
and Report Revised: 2003-04-17

### DESCRIPTION

#### PRODUCT COVERED:

USL, CNL Wireways with associated fittings, 2-1/2 by 2-1/2 in. through 12 by 12 in.

Applicable Standards: UL 50E Enclosures for Electrical Equipment, Environmental Considerations  
UL 870 "Wireways, Auxiliary Gutters and Associated Fittings"  
CSA-C22.2 No. 26 "Construction and Test of Wireways, Auxiliary Gutters and Associated Fittings."  
cUL to CSA C22.2 No. 94.2

Authorized by:



2/18/2022

**Tom Hurney**

**Date**

Technology Mgr., Product Compliance and Approvals

DOC: CERT-00151 C

Subject to Change Without Notice

# CERTIFICATE OF COMPLIANCE

Certificate Number E27524  
Report Reference E27524-19630627  
Date 2021-January-15

Issued to: Hoffman Enclosures Inc  
2100 Hoffman Way  
Anoka MN, 55303-1738 US

This is to certify that  
representative samples of

WIREWAY, AUXILIARY GUTTERS AND ASSOCIATED  
FITTINGS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 870 - Wireways, Auxiliary Gutters, and Associated  
Fittings

C22.2 No. 26-13 - Construction and Test of Wireways,  
Auxiliary Gutters and Associated Fittings


Additional Information:

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahresholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [local@ul.com/about/certification](mailto:local@ul.com/about/certification)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E27524  
**Report Reference** E27524-19630627  
**Date** 2021-January-15


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Wireways Cat. Nos. F followed by 22, 44, 66, 88, 1010 or 1212 followed by T1 followed by 12, 24, 36, 48, 60, 72 or 120, followed by GV or GVP, may be followed by WK.

Wireways Cat. Nos. F followed by 22, 44, 66, 88, 1010, 1212 followed by G followed by 12, 24, 36, 48, 60, 72 or 120, may be followed by WK.

Wireway Fittings Cat. Nos. F followed by 22, 44, 66, 88, 1010, 1212 followed by G90E, G90EOUT, 90EIN, GT, T, G90TX, G45E, GUC, GCP, GCPNK, GSH, GDB, GOA, GPA or G90SE.

Wireway Fittings Cat. No. F44G22R.



Bruce Mahreholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/carbonx/>

