

# Certificate of Compliance

**Certificate Number:**

[E492323]

**Report Reference:**

E492323-20170418

**Issue Date:**

2024-January-16

Issued to:

**Hoffman Enclosures Inc  
2100 Hoffman Way  
Anoka, MN 55303-1738 United States**

This certificate confirms that representative samples of:

**Luminaires for Use in Hazardous Locations  
See Addendum Page**

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

**[See Addendum Page]**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# Certificate of Compliance

**Certificate Number:** E492323  
**Report Reference:** E492323-20170418  
**Issue Date:** 2024-January-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.]

## Standard No. & Title

UL 844, LUMINAIRES FOR USE IN HAZARDOUS (CLASSIFIED) LOCATIONS.

CSA C22.2 NO. 137-M1981, ELECTRICAL LUMINARIES FOR USE IN HAZARDOUS LOCATIONS.

UL 8750, LIGHT EMITTING DIODE (LED) EQUIPMENT FOR USE IN LIGHTING PRODUCTS.

UL 1598 & CSA C22.2 NO. 250.0-08, LUMINAIRES.

UL 2108, Low Voltage Lighting Systems.

CSA C22.2 NO. 250.13-14, LIGHT EMITTING DIODE (LED) EQUIPMENT FOR LIGHTING APPLICATIONS.

# Certificate of Compliance

**Certificate Number:** E492323  
**Report Reference:** E492323-20170418  
**Issue Date:** 2024-January-16

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G.  
Models LEDHL24V12, LEDHL24V24, LEDHL24V36, LEDHL24V48.

## Ratings:

### AMBIENT TEMPERATURE RATINGS:

Temperature Ambient: -40°C to +65°C for 120VAC Models.  
-40°C to +60°C for all other Models.

### TABLE II

Operating Temperature Codes for GS Models

Luminaire Voltage Rating	Maximum Rated Ambient Temperature	Class I, Div. 2 Groups A,B,C,D MIN.	Class II, Div. 2 Groups F,G MIN.	Simultaneous Exposure Rating Class I, Div. 2; Class II, Div. 2
DC	60°C	T4	T6	T3C
AC	65°C	T5	T4A	T3C