



ERICO France Sarl
Rue Charles Dallière BP 31
42161 Andrézieux-Bouthéon
FRANCE

Client no.
610805

Your reference
Frederic Bizet

Our reference
Thomas Koller

Date
10.06.2022

Authorization

Number: **22.0452**
valid until: **09.06.2025**

Marking:



Based on the documents contained in file **22-BS-0198**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment: **Flexbus System**

Tradename: **nVent ERIFLEX**

Type designation	Nominal values				
FLEXCOND220	1000V AC	1500V DC	400kVA	560A	50/60Hz
FLEXCOND360	1000V AC	1500V DC	500kVA	704A	50/60Hz
FLEXCOND545	1000V AC	1500V DC	630kVA	900A	50/60Hz
FLEXCOND640	1000V AC	1500V DC	800kVA	1120A	50/60Hz
FLEXCOND960	1000V AC	1500V DC	1000kVA	1400A	50/60Hz
FLEXCOND1280	1000V AC	1500V DC	1250kVA	1760A	50/60Hz
FLEXCOND1810	1000V AC	1500V DC	1600kVA	2253A	50/60Hz





Authorization Number: **22.0452**

Protection class:

Protection degree: IP55

Basis: Test Report / F-Lab Volta / 202104106_001 / 20.07.2021
Test Report / F-Lab Volta / SPEC21AA1027_V2 / 21.01.2022

Remark:

Test standards: IEC 61439-1(ed.3):2020
IEC 61914(ed.3):2021
IEC 60364-5-52(ed.3):2009
IEC 60364-4-42(ed.3):2010

Federal Inspectorate for Heavy Current Installations ESTI

Peter Fluri
Head of Market Surveillance/Safety Mark

