



EMPLOYER ROADS AND TRANSPORT AUTHORITY هيئة الطرق و المواصلات ROADS & TRANSPORT AUTHORITY	CONSULTANT LOUIS BERGER  R Louis Berger	CONTRACTOR HABTOOR LEIGHTON GROUP 
---	--	--

MATERIAL APPROVAL FORM

CLIENT : <u>ROADS & TRANSPORT AUTHORITY</u> CONSULTANT : <u>LOUIS BERGER COMPANY</u> CONTRACTOR : <u>HABTOOR LEIGHTON GROUP</u> PROJECT : <u>UPGRADE JUNCTIONS AT AIRPORT ROAD</u> PROJECT NO. : <u>R1011/2</u>	MATERIAL SUBMISSION : R1011-2 -HLG-MS-0062 SUBMISSION NO. : Rev. 00 PREVIOUS SUBMISSION REF : (IF SUBMITTED) RECEIVED 24/12/15
--	---

DESCRIPTION	Mechanical Coupler for Reinforcement Bars- Lenton
DATE OF SUBMISSION	24/12/2015
DATE OF APPROVAL	
REQUESTED BY DATE	ASAP
B O Q REF.	N/A
SPECIFICATION REF.	N/A
DRAWING NO & STATUS	
CONSTRUCTION DRAWING	
NAME & ADDRESS OF MANUFACTURER	Erico Lenton, Taiwan
LOCAL AGENT	Alam Steel Industries/ Emirates Specialists, UAE
TECHNICAL LITERATURE	As attached
SAMPLE	N/A



CONTRACTOR CONSULTANT: LOUIS BERGER COMPANY <input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> APPROVED AS NOTED <input type="checkbox"/> RESUBMIT <input type="checkbox"/> REJECTED	NAME: Marnoun Shahin CLIENT: DUBAI ROADS & TRANSPORT AUTHORITY <input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> APPROVED AS NOTED <input type="checkbox"/> RESUBMIT <input type="checkbox"/> REJECTED
---	---

Consultant Comments: Source is already approved for the RTA project R-1011/2 Approval subject to comply with Standard & Manufacturer Technical literature People delivered at site should be tested at DCL Manufacturer test certificates shall be provided along with each delivery of site to be checked before use 31/12/15	Client Comments: Accepted as Recommended by Consultant and subject to his comments in addition, Random samples to be collected for testing during work Consultant Approval to be obtained for every single use 01/01/2016
--	---

AUTHORISED SIGNATURE & DATE

- NOTE:
1. RTA no objection does not relieve either the Consultant or Contractor of their responsibilities Under the Consultancy Agreement of Contract
 2. All relevant test results required by specification to be attached

Rec 25/12/15
03/1/16