

CONNECT AND PROTECT

HWAT System – Insulation Schedule of Non-Static Supply Piping

APPLICATION DESIGN NOTE

One requirement for a successful hot water temperature maintenance system is to use the correct insulation type and thickness.

The standard fiberglass insulation thickness schedule from the HWAT Product Selection and Design Guide (H57538) is shown in the table below. This schedule provides constant heat loss for all pipe sizes and results in uniform temperature maintenance with the nVent RAYCHEM Hot Water Temperature Maintenance (HWAT) system. If different thicknesses are used, pipe temperatures will vary.

INSULATION SCHEDULE

Copper pipe size (in)	IPS insulation size (in)	Insulation thickness (in)
1/2	3/4	1/2
3/4	1	1
1	1 1/4	1
1 1/4	1 1/2	1 1/2
1 1/2	1 1/2	1 1/2
2	2	2
2 1/2	2 1/2	2 1/2
3	3	3

Note

For pipes 3 inches and larger, the thickness of insulation can be equal to the pipe diameter with one run of heating cable or 1/3 the pipe diameter with two runs of heating cable.

For supply mains greater than 2 inches in diameter, the insulation schedule in Table 1 may present some difficulty due to the space required to accommodate the insulation. If this is a problem, reduce the insulation thickness to 1/3 of that specified and install two runs of HWAT heating cable.

The reason the insulation thickness is so critical for HWAT systems is that the pipes are assumed to be static for long periods of time. Using the specified insulation size and thickness ensures the pipes will be at the correct and uniform temperature. However, large diameter pipes are not likely to remain static for prolonged periods of time in large installations such as hospitals and hotels. In these pipes hot water is frequently added to the pipe system replacing the cold water and reducing the effective heat loss of the pipes.

For these situations an alternative insulation schedule has been created for HWAT systems on copper pipes 2 1/2 inches or larger with constant but low flow. The mains can be insulated with only 2 inches of fiberglass thermal insulation and use a single run of HWAT heating cable if the minimum flow is maintained. Fig. 1 shows the flow rate required to have less than 1°F temperature drop for every 50 feet of supply pipe.




Fig. 1 Flow rate required to maintain* pipe temperature with a single run of HWAT heating cable

* Less than 1°F temperature drop for every 50 feet of supply pipe

Using this approach, HWAT systems can maintain uniform pipe temperatures throughout the system with thinner insulation on the main supply pipe and standard insulation on the branch pipes.

Install in accordance with the HWAT System Installation and Operation Manual (H57548) and the nVent RAYCHEM HWAT-ECO-GF Installation and Maintenance Manual (H60223).

Approvals and performance are based on using nVent Thermal Management approved connection kits and accessories, do not substitute parts.

North America

Tel +1.800.545.6258
 Fax +1.800.527.5703
 thermal.info@nVent.com



Our powerful portfolio of brands:

CADDY ERICO HOFFMAN RAYCHEM SCHROFF TRACER